

**MGOZ/MPU T 25/2017 - Tender for the supply and delivery of Pipes and Fittings at
Villa Rundle Gardens**

Clarification No. 1

Question

Please provide dimensions, pressure rating and material for items 8, 9, 10 and 11 in the BOQ.

Answer

The dimensions and material of Items 8, 9, 10, 11 as listed in the Bill of Quantities are specified in the technical specifications as depicted in the following table.

Item in Bill of Quantities	Reference in Section 4 - Technical Specifications of the Tender Document
8 – Supply and Delivery of Clamp Saddles	2.2.2 – Drip Tube Fittings
9 – Supply and Delivery of Ball Valves	2.2.3 – Drip Tube Ball Valves
10 – Supply and Delivery of End Plugs	2.2.4 – Drip Tube End Plugs
11 – Supply and Delivery of Elbows	2.2.2 – Drip Tube Fittings

With regards to pressure rating, all the items shall be rated at a minimum pressure rating of 4 bar.