

# Ministerial Procurement Unit

Directorate General (Operations)  
Head Office



t +356 22156272  
e mpu.mgoz@gov.mt

MINISTRY FOR GOZO  
HEAD OFFICE DG OPERATIONS, ST. FRANCIS  
SQUARE,  
IR-RABAT, GOZO, MALTA

15<sup>th</sup> October 2018

**REFERENCE NUMBER: MGOZ/MPU T 57/2018**

**TENDER FOR REGENERATION WORKS AT THE WATER PUMPING STATION AT ZEWWIEQA  
IN MGARR HARBOUR, GOZO.**

## Clarification No. 1

Reference is made to the above-tender, for which deadline for submission of offers is the 26<sup>th</sup> October 2018 at 09.30am.

**Question 1:** Kindly specify type of material to be used for partition wall as per item 2.01 of the BOQ

**Answer 1:** Wall should be constructed in pre-cast hollow concrete blocks consistent with item 2.00 of the BOQ.

**Question 2:** Kindly confirm that unit of measurement for item 4.00 is per cum

**Answer 2:** Confirmed

**Question 3:** Kindly confirm size of plywood sheets to be quoted per number as per item 4.01 of the BOQ

**Answer 3:** Please refer to article 16 of Section 4 of the tender dossier

**Question 4:** Kindly clarify what is the type of gypsum boards to be used for item 5.01

**Answer 4:** Standard gypsum boards are required

**Moreover, the Contracting Authority wishes to notify bidders of the following changes in cross referencing between the tender specifications [Section 4] and the Bill of Quantities:**

- 1. Specifications in Part 2 of Section 4 – makes reference to item 2.03 – concrete works of the BOQ*
- 2. Specifications in Part 3 of Section 4 – makes reference to item 2 – construction works of the BOQ*
- 3. Specifications in Parts 4, 5, 6, 7, 8, 9, 10, and 10.1 of Section 4 – are outside the scope of this tender and are not to be considered*
- 4. Specifications in Parts 11, 12 and 14 of Section 4 – makes reference to item 5.04 of the BOQ*

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.