



29th November 2018

REFERENCE NUMBER: GCOL T 03/2018 (MPU)

Tender for the provision of servicing and repairs of fire fighting equipment/breathing apparatus equipment to Gozo Channel (Operations) Limited

Clarification No. 1

Reference is made to the above tender, for which deadline for submission of offers is the 11th December 2018 at 09.30am.

Question 1: Please advise the dates when these were undergone hydro pressure testing and what type of valves are installed?

Answer 1: The dates when hydro pressure testing was carried out and the type of valves installed are as per below:

MV ta Pinu

Last Hydro pressure testing of BA cylinders: **22 cyl Jan 2014, 2cyl Dec 2017**
Last Hydro pressure testing of 45 kgs Co2 Cylinders: **10 cyl Jan 2010, 9cyl March 1998**
Last Hydro pressure testing of 1.8 kgs pilot cylinders: **March 1997**
Last Pressure test of 2 valves: **May 2015**
Type of co2 valves: **Ball Valve DN50**

MV Gaudos

Last Hydro pressure testing of BA cylinders: **Nov 2014**
Last Hydro pressure testing of 45 kgs Co2 Cylinders: **6 cyl Feb 1996, 3 cyl June 1996, 10 cyl Jan 2008**
Last Hydro pressure testing of 1.8 kgs pilot cylinders: **2cyl Nov 2017, 2 cyl June 2017**
Last Pressure test of 2 valves: **April 2014**
Type of co2 valves: **Ball Valve DN 50**

MV Malita

Last Hydro pressure testing of BA cylinders: **21 cyl Jan 2015, 3 cyl Nov 2014**
Last Hydro pressure testing of 45 kgs Co2 Cylinders: **9 cyl Sept 1998, 10 cyl Feb 2010**

Last Hydro pressure testing of 1.8 kgs pilot cylinders: **June 1997**
Last Pressure test of 2 valves: **Jan 2015**
Type of co2 valves: **Ball Valve DN 50**

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.
