



10th December 2018

REFERENCE NUMBER: MGOZ/MPU/ T 77/2018

Tender for the Supply, Installation, Testing and Commissioning of Mechanical and Electrical Services for the Gurdan Lighthouse, Ghasri, Gozo,

Clarification No. 1

Minutes of Clarification Meeting/Site Visit held on 5th December 2018.

Reference is made to the above-tender, for which deadline for submission of offers is the 19th December 2018 at 09.30am.

The Site Visit opened with the Contracting Authority highlighting the objectives of the tender. The following questions were asked and answered:

- Q1) With regards to the passing of services under floor, how will it be carried out?
- A1) Services will be passed under the existing floor, where necessary and if no other options are available. Existing floor tiles or stone slabs will be removed carefully by hand (by the Contractor), in order to avoid damage to the tiles or slabs. When the necessary services are laid out, the same tiles or slabs will be re-laid as originally put. Where the existing floor is textured cement floor, this area cannot be affected and any sub-floor services must be routed in an alternative way.
- Q2) How will the work be carried out in locked rooms?
- A2) All the locked rooms or areas which are currently unavailable, will be opened or made available on request, until the necessary works are carried out.

All other terms and conditions remains the same.

Unless otherwise instructed by the Contracting Authority, ALL other terms and conditions within the Tender Dossier and/or published sets of clarifications remain valid and unaltered.