

Ministerial Procurement Unit

Directorate General (Operations)
Head Office



t +356 22156272
e mpu.mgoz@gov.mt

MINISTRY FOR GOZO
HEAD OFFICE DG OPERATIONS, ST. FRANCIS
SQUARE,
IR-RABAT, GOZO, MALTA

29th March 2018

REFERENCE NUMBER: MGOZ/MPU/ T 18/2018

Tender for the Asphaltting Works at Triq il-Gebbla tal-General in San Lawrenz, Gozo

Clarification No. 2

Q1: With reference to your reply for request for clarification 1 can you please specify "Polished Stone Value" for aggregate to be used?

A1: Polished Stone Value of aggregate to be used should be grater or equal to 45

All other terms and conditions remain the same.