

Ministerial Procurement Unit

Directorate General (Operations)
Head Office



t +356 22156272
e mpu.mgoz@gov.mt

MINISTRY FOR GOZO
HEAD OFFICE DG OPERATIONS, ST. FRANCIS
SQUARE,
IR-RABAT, GOZO, MALTA

6th March 2018

REFERENCE NUMBER: MGOZ/MPU/ T 13/2018

TENDER FOR THE SUPPLY AND DELIVERY OF PVC PIPES TO THE PROJECTS AND DEVELOPMENT DIRECTORATE WITHIN THE MINISTRY FOR GOZO

Clarification No. 1

Reference is made to the above-tender, for which deadline for submission of offers is the 26th March 2018 at 09.30am.

Question 1: Should the pipes have a specific length each or it's only important the total of 460 meters?

Answer 1: No specific length for each pipe is being requested. Bidders are being requested to quote for the total requested length of 460m.

Question 2: Please note that referring to SN4 the corresponding SDR is SDR 41 and not SDR 51 as mentioned in the tender. SDR 51 refers to SN2. Please clarify.

Answer 2: The specification 'Class Rigidity SN4 SDR 51' should read 'Class Rigidity SN4'. For clarity, the pipes must conform to the following standards and specifications:

- complying to BS EN 140-1:1998 Type UNI 303/2,
 - Class Rigidity SN4
 - with 400mm diameter
-