



4<sup>th</sup> July 2019

**REFERENCE NUMBER: MGOZ/MPU T 34/2019**

**Tender for the ground investigations at proposed Park & Ride Facility at Ta' Xhajma area within the limits of Xewkija, Gozo**

**Clarification No. 4**

---

**Clarifications**

---

Question 1: What is the number of bore holes and depth?

**Answer 1: In line to the financial bid form, this tender covers quantity 36 Bore Holes with Full Recovery and Ground Investigation Report in accordance with Eurocode 7 -part 1) including drilling water supply. Location of holes shall be as instructed by the architect in charge. Bidder is to quote a rate per metre. Maximum depth per borehole is of 25 metres. Bidders are to quote also a lump-sum for Mobilisation\Demobilisation.**

Question 2: Testing of Clay? Which tests? How many?

**Answer 2: Please refer to Clarification Note 3.**

Question 3: Surveyor to mark site?

**Answer 3: Please refer to Clarification Note 3.**

Question 4: Mepa Permit Number?

**Answer 4: Please refer to Clarification Note 3.**

Question 5: If rock is not found should we go deeper?

**Answer 5: Please refer to Clarification Note 3.**

---

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.