



16th April 2020

REFERENCE NUMBER: MGOZ/MPU T 33/2020

**TENDER FOR THE PAVING, RESTORATION AND RENOVATION OF THE RAVELIN AT
CITTADELLA, VICTORIA, GOZO**

Clarification No. 1

Reference is made to the above-tender, for which deadline for submission of offers is the 29th April 2020 at 09.30am.

- Q1) Can you please clarify if the existing paving is to be take up? If yes kindly indicate BOQ item for such works
- A1) The existing paving will be removed by the Ministry's own personnel prior the start of works of this tender.
- Q2) Item 2.05 states that two layers membrane are to be laid; can you please clarify if rate is to be per single layer or else for the 2 layers?
- A2) The rate should be for a single layer of membrane.
- Q3) Please provide more details regarding item 4.03; shall this include the supply and lay of hardstone kerb around both trees?
- A3) The rate being requested is for the tree positioned to the front of the ravelin. Works include the construction of circular dug out, which is to be constructed out of good quality lower coraline limestone as per tender specifications. Rate is to include supply, bedding, laying and pointing of joints with approved mortar.

All other terms and conditions remain the same.

Unless otherwise instructed by the Contracting Authority, ALL other terms and conditions within the Tender Dossier and/or published sets of clarifications remain valid and unaltered.