

Ministerial Procurement Unit

Directorate General (Operations)
Head Office

t +356 22156272
e mpu.mgoz@gov.mt



MINISTRY FOR GOZO
HEAD OFFICE DG OPERATIONS, ST. FRANCIS
SQUARE,
IR-RABAT, GOZO, MALTA

17th March 2020

REFERENCE NUMBER: MGOZ/MPU T 83/2019

Tender for the supply, delivery, installation, testing and commissioning of a lightning protection system at the Gurdan lighthouse in Ghasri, Gozo

Clarification No. 2

Reference is made to the above-tender, for which deadline for submission of offers is Monday 23rd March at 09.30am.

Clarification Meeting/Site Visit held on Wednesday 11th March 2020 at 10:00.

Venue: Gurdan Lighthouse, Ghasri, Gozo.

The clarification meeting commenced with the engineer in charge giving a detailed outline of the objectives of the tender.

One clarification was requested as following:

Question: *Can we fix a stainless steel plate on the top concrete platform using 15mm studs?*

Answer: *One can fix a stainless steel plate to the concrete platform. It is important to note that the platform contains a metal mesh. Only stainless steel studs can be used and any holes drilled must be cleaned and filled with chemical anchor before inserting the studs. The contractor must ensure that the holes are perfectly sealed.*

No other questions were raised.
