

Ministerial Procurement Unit

Directorate General (Operations)
Head Office

t +356 22156272
e mpu.mgoz@gov.mt



MINISTRY FOR GOZO
HEAD OFFICE DG OPERATIONS, ST. FRANCIS
SQUARE,
IR-RABAT, GOZO, MALTA

29th October 2020

REFERENCE NUMBER: MGOZ/MPU T 88/2020

Tender for the supply, delivery and installation of new air condition units for the social work unit within the Ministry for Gozo

Clarification No. 2

CLARIFICATION MEETING/ SITE VISIT MINUTES

Clarification meeting/Site visit held on Tuesday 27th October 2020 at 10:00hrs

Meeting place: Entrance of Tigrinja Palazz in Republic street, Victoria

The scope of the project was explained to the prospective bidders present for the meeting and they were later shown the site where installations are to take place.

Those present were invited to make questions and the following were asked and replied:

Question 1: Shall the installation of drain pipes include insulation?

Answer 1: **As per tender document, Section 3 – Specifications, ‘Insulation: All piping and accessories shall be properly insulated and finished in a smooth, clean workman like manner with all joints tightly finished.’**

Question 2: How shall the copper pipes be routed above the false ceiling?

Answer 2: **Copper pipes shall be clipped to the concrete ceiling.**

Question 3: What type of remotes shall be offered? Wired or wireless?

Answer 3: Both type of remotes are acceptable.

Question 4: Is it possible to have a drawing of the installation area?

Answer 4: In line to the technical terms of the tender document, please find the drawing of the installation area below.



All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.