



t +356 22156272
e mpu.mgoz@gov.mt

MINISTRY FOR GOZO
HEAD OFFICE DG OPERATIONS, ST. FRANCIS
SQUARE,
IR-RABAT, GOZO, MALTA

19th February 2021

REFERENCE NUMBER: MGOZ/MPU T 17/2021

Tender for the supply and delivery of electrical material for the Engineering Section within the Ministry for Gozo

Clarification No. 1

Clarification

Question 1: Lot 3
Since you need 16mm colour coded insulated cables. Will you accept PVC H07V-K 750V instead of XLPE 1KV?

Answer 1: **As per Section 3 of the tender document, the required cables shall conform to the following: “Non-armoured cable, cross link polyethylene insulated and polyvinyl chloride sheathed (XLPE/PVC) with multi-stranded copper conductor with voltage grade of 0.6/1kV conforming to BS 5467”. No other type of cable will be accepted.**

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.