



L-UFFIĊĊJU TAL-PRIM MINISTRU

MALTA

OFFICE OF THE PRIME MINISTER

*Direttorat għall-Akkwist Settorjali*

*Sectoral Procurement Directorate*

9<sup>th</sup> July 2021

**REFERENCE NUMBER: SPD3/2021/030**

**TENDER FOR THE DESIGN, SUPPLY, DELIVERY AND INSTALLATION OF LABORATORY FURNITURE AT THE GOVERNMENT EXPERIMENTAL FARM, MINISTRY FOR GOZO, IN THE CONTEXT OF THE INTERREG ITALIA-MALTA SIMASEED PROJECT - SIMASEED PROCUREMENT 8 (2021)**

**Clarification No. 1**

---

**Clarification**

---

Question 1: Item 5: High Cabinets

The item title indicates this is a high unit however the last bullet in the specs says that you need the cabinets to have a minimum height of 60cm, which makes it a low unit. Can you kindly clarify? Also, can you please give an indication of the depth of the cabinets?

**Answer 1:** By 'high unit cabinets', the Contracting Authority intends cupboards installed over the work top benches at a height higher than eye level. Therefore, as per Item 5 in Section 3 of the tender document, the cabinets under Item 5 need to have a minimum height of 60cms.

**As per normal standard and as shown in the published drawings, high units should have a depth which is less than the work top benches, thus ensuring that the space on the work top benches remains easily accessible.**

---

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.

*Sectoral Procurement Unit 3*  
*Sectoral Procurement Directorate*