



10th March 2021

REFERENCE NUMBER: MGOZ/MPU T 21/2021

TENDER FOR THE SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF MECHANICAL AND ELECTRICAL SERVICES AND FINISHES INCLUDING THE USE OF ENVIRONMENTALLY FRIENDLY PAINTING MATERIAL AT THE MGOZ OFFICES AT G.B. OLIVIER STREET, VICTORIA, GOZO

Clarification No. 2

Clarification Request

Question 1: We are finding it extremely difficult to find a 360 degrees detector that meet all the requested specs; considering that 3 of the detectors are to be installed in a corner, and that the remaining 4 detectors can easily be mounted in the corner as well and still providing optimal coverage, is it possible to supply for a ceiling/wall mount detector with 90 degrees coverage, meeting all the other specs, and install the said detector in the corners of the areas to be covered?

Answer 1: As per Clause 2.3 in Section3, Part 1 of the tender document, “The intruder detector shall be of the dual technology type with microwave and PIR combined technology, EN Grade 2, class II, mountable in false ceiling with 360° coverage, 15m volumetric range, X-band microwave frequency, white polycarbonate enclosure complete with LED lights to indicate detector’s operation, anti-tampering, and high immunity to false alarms.” No other type of Intruder Detector will be accepted.

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.