



1<sup>st</sup> October 2021

REFERENCE NUMBER: SPD3/2021/058

**TENDER FOR THE SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF VERTICAL TRANSPORTATION SYSTEMS FOR VILLA LAURI**

**Clarification No. 1**

---

**Clarifications**

---

**Question 1:** Regarding the subject tender in question could you please confirm the shaft size as on drawings the shaft size is 1600mm wide x 1930mm deep which contradicts the Tenderer's technical offer as it states on page one 1900mm wide x 1600mm deep.

**Answer 1:** It is clarified that bidders are to consider correct the dimensions provided as per the Technical Offer, i.e. the size of the shaft is 1600mm x 1900m.

---

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.

*Sectoral Procurement Unit 3  
Sectoral Procurement Directorate*